



Wastewater Treatment Utility
 500 South River Road
 West Lafayette, Indiana 47906
 Voice: (765) 775-5145
 Fax: (765) 775-5149

MONTHLY REPORT OF OPERATIONS

National Pollutant Discharge Elimination System -- NPDES

March 2015--MONTHLY AVERAGES

Limit

TSS	8	mg/l	(30.00)
CBOD	3.9	mg/l	(25.00)
NH ₄	0.08	mg/L	(6.00)
Cl ₂	N/A	mg/L	(0.06)
E. COLI	N/A	#/100ml	(125.00)
FLOW TOTAL	256.9	MG	
	AVG	8.29	MGD
	MAX	11.75	MGD
	MIN	6.82	MGD
PRECIPITATION	2.02	INCHES	

March 2015--PERCENT REMOVALS

TSS	95.2	REPORT ONLY
CBOD	97.6	REPORT ONLY
Ammonia	99.6	REPORT ONLY
Phosphorus	36.9	REPORT ONLY

COMBINED SEWER OVERFLOWS

March 2015	MG	HOURS	Events
TOTAL FLOW	256.91		
PERCENT TREATED	99.9981		
OVERFLOW POINT			
DEHART STREET	0.0030	5.08	2
QUINCY STREET	0.0020	7	2
Wet Weather Treatment Facility	0.0000	0	0
OVERFLOW TOTAL	0.0050	12.08	4